


HEALTH DEPARTMENT DISTRICT JIND



Hygienic Certificate



Certified that Dy. Civil Surgeon School (Health) O/o Civil Surgeon Jind inspected the premises on 10.06.2025 and found the hygienic and sanitation condition of Jiet Convent School JIND satisfactory for the year 2025-26.

Memo No. Hygienic/CSJind/ 45
Dated : 10/6/2025

Principal
Jiet Convent School
Jind (Haryana)

For Jind Education Trust

Chairman

Dy. Civil Surgeon (Health)
For Civil Surgeon Jind.

10/6/2025



Memo No:- 1510

Date:- 28/05/2025

Certificate
No: TC-4072

Subject: Physical / Chemical Examination Report of Water Sample

Sample ID/Classification :- JND/02211/5/2025 / Private	Sample Details	Date & Time
Sender :- JIET CONVENT SCHOOL	Collected By	Rakesh Sharma
Location :- JIET CONVENT SCHOOL SAFIDON ROAD JIND	Collection Date	26/05/2025 at 10:44
Sample Description :- Drinking Water	Received at lab	26/05/2025 at 15:36
Latitude / Longitude :- 76.354169 / 29.329167	Analysis Start Date	26/05/2025
	Analysis End Date	26/05/2025
	Sample Quantity	2ltr

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.22	1 NTU	5 NTU	APHA 24th Edition-2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1984 (2023)
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):1984 (2018)
4	Color	5.0	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120-B
5	Total Dissolved Solids @ 180°C ± 2°C	178	500 mg/lit.	2000 mg/lit.	APHA 24th Edition-2540 C
6	Total Hardness as CaCO ₃	56	200 mg/lit.	600 mg/lit.	APHA 24th Edition-2340 C
7	Calcium as Ca	5.61	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	10.21	30 mg/lit.	100 mg/lit.	APHA 24th Edition-3500 Mg B
9	Total Alkalinity	44	200 mg/lit.	600 mg/lit.	APHA 24th Edition-2320 B
10	Chloride as Cl	31.21	250 mg/lit.	1000 mg/lit.	APHA 24th Edition-4500 Cl-B
11	Sulphate as SO ₄	21	200 mg/lit.	400 mg/lit.	APHA 24th Edition-4500 SO ₄ E
12	Fluoride as F	0.25	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C
13	Iron as Fe	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA, APHA 24rd Edition-3500 Fe B
14	Nitrate as NO ₃	0.30	45 mg/lit.	45 mg/lit.	APHA 24th Edition-4500 NO ₃ D
15	pH @ 25°C	7.35	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition-4500-H+ B

Remarks:-

- The Results Given above are related to the sample as received and tested in PHED JIND Lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or any legal purpose.
- Reliability of water sample sample lies with sender/collector of water sample.
- To check the sample report online Scan the QR Code below.
- The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.

Sample analyzed by:

VIRENDER, CHEMIST
DISTRICT WATER TESTING LABORATORY, JIND
email:- chemist.jind@phedharyana.gov.in

Principal
Jiet Convent School
Jind (Haryana)

For Jind Education Trust

Chairman