

APPENDIX - XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. PHD/28/391

Dated: 28-07-2025

It is certified that an inspection team headed by KARANDEER SINGH SDO

(Name of Officers with designation) from Public Health Department

(Name of Department/ Office) inspected the JIET CONVENT SCHOOL, SAFIDON ROAD, NEAR SECTOR-09, JIND HARYANA on 28th July 2025 and found that the (JIET CONVENT SCHOOL) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

The above is valid for a period of One year

SDO [Signature]
Public Health Deptt

Signature with Seal: Jind

Name: KARANDEER SINGH

Designation: SDO

Name & Address of the Office / Department: Public Health Deptt
Jind.

[Signature]
Manager
Jiet Convent School
Jind, (Haryana)

[Signature]
Principal
Jiet Convent School
Jind (Haryana)

Memo No:- 1510

Date:- 28/05/2025

Certificate
No: TC-4072

Subject : Physical / Chemical Examination Report of Water Sample

Sample ID/Classification :	JND/02211/5/2025 / Private	Sample Details	Date & Time
Sender :	JIET CONVENT SCHOOL	Collected By	Rakesh Sharma
Location :	, JIET CONVENT SCHOOL SAFIDON ROAD JIND	Collection Date	26/05/2025 at 10:44
Sample Description :	Drinking Water	Received at lab	26/05/2025 at 15:36
Latitude / Longitude :	76.354169 / 29.329167	Analysis Start Date	26/05/2025
		Analysis End Date	28/05/2025
		Sample Quantity	2ltr

Test Result (As Per BIS 10500 :2012)

S.No.	Tested Parameter	Result	Requirement (Acceptable Limit)	Permissible Lmt. (In the Absence of Alternate Source)	Protocol Used
1	Turbidity	0.22	1 NTU	5 NTU	APHA 24th Edition-2130 B
2	Taste	Agreeable	Agreeable	Agreeable	IS 3025 (Part-8):1984 (2023)
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5):1984 (2018)
4	Color	5.0	5 Hazen Units	15 Hazen Units	APHA 24th Edition-2120-B
5	Total Dissolved Solids @ 180°C ± 2°C	178	500 mg/lit.	2000 mg/lit.	APHA 24th Edition-2540 C
6	Total Hardness as CaCO ₃	56	200 mg/lit.	600 mg/lit.	APHA 24th Edition-2340 C
7	Calcium as Ca	5.61	75 mg/lit.	200 mg/lit.	APHA 24th Edition-3500-Ca B
8	Magnesium as Mg	10.21	30 mg/lit.	100 mg/lit.	APHA 24th Edition-3500 Mg B
9	Total Alkalinity	44	200 mg/lit.	600 mg/lit.	APHA 24th Edition-2320 B
10	Chloride as Cl	31.21	250 mg/lit.	1000 mg/lit.	APHA 24th Edition-4500 Cl-B
11	Sulphate as SO ₄	21	200 mg/lit.	400 mg/lit.	APHA 24th Edition-4500 SO ₄ E
12	Fluoride as F	0.25	1.0 mg/lit.	1.5 mg/lit.	APHA 24th Edition-4500F C
13	Iron as Fe	0.02	1.0 mg/lit.	1.0 mg/lit.	USEPA, APHA 24rd Edition-3500 Fe B
14	Nitrate as NO ₃	0.30	45 mg/lit.	45 mg/lit.	APHA 24th Edition-4500 NO ₃ D
15	pH @ 25°C	7.35	6.5 - 8.5	6.5 - 8.5	APHA 24th Edition-4500-H+ B

Remarks :-

- * The Results Given above are related to the sample as received and tested in PHED JIND Lab.
- * The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- * The test report can't be used for any publicity or any legal purpose.
- * Reliability of water sample sample lies with sender/collector of water sample.
- * To check the sample report online Scan the QR Code below.
- * The test samples meant for chemical analysis will be disposed off after 7 days from the date of issue of test report unless until specifically requested by the customer for retaining over a longer period.



Sample analyzed by :

VIRENDER ,CHEMIST
DISTRICT WATER TESTING LABORATORY,JIND
email:-chemist.jind@phedharyana.gov.in

Manager
Jiet Convent School
Jind, (Haryana)

Principal
Jiet Convent School
Jind (Haryana)